

Portable Fire Extinguishers & Hose Stations - GREENHOUSE

Monthly Report

S = Satisfactory US = Unsatisfactory N/A = Not Applicable

Ensure fire extinguishers are charged, have not been tampered with and are undamaged. Also check nozzle for obstructions, seal or tamper indicators are in place, pressure gauge reading in operable range, no signs of physical or mechanical damage, operation instructions on nameplate legible and face outwards and access and visibility of extinguisher not obstructed.

Inspect hose stations to ensure hose in its proper position and all equipment is in place and in operable condition.

B21570 – GREENHOUSE COMPLEX plus B25685 – NEW GREENHOUSE

LOCATION EXTINGUISHER/HOSE CABINET	TYPE	SIZE	SERIAL#	J	F	M	A	M	J	J	A	S	O	N	D	NAME (PRINT)	SIGNATURE
NEW GREENHOUSE BY NORTH DOOR	ABC	5 LB	269290C													JAN 200	_____
EAST BOILER ROOM	ABC	5 LB	929442													FEB 200	_____
BOILER ROOM	ABC	5 LB	86571C													MAR 200	_____
WORKSHOP	ABC	5 LB	761416													APR 200	_____
WORKSHOP	ABC	5 LB	761418													MAY 200	_____
COR. BY OFFICE	ABC	5 LB	356860C													JUN 200	_____
																JUL 200	_____
																AUG 200	_____
																SEP 200	_____
																OCT 200	_____
																NOV 200	_____
																DEC 200	_____